

Project: Building Checks With Pupils
Subject: Technical Report from Engineering Check
Date: September 2019

*Dr. Giorgos Fragkogiannis
Min Eng NTUA
Geothermal HVAC Expert
44 Adelfon Pierrakou St. 15771
Zografou, Attica*

*Email: pfengin@gmail.com
Mob: +6973666960 phone: +30 210 5221232*

*Athens
September 2019*

INTRODUCTION - SCOPE OF PROJECT – METHODOLOGY

In the present report illustrated the main findings, notes and proposals from Engineers that participate in project: “Building checks with pupils” as a part of the biggest project of climate schools Be.AT (Berlin – Athens)

During this project several technical visits from Engineers performed in ten (10) Public school of municipal of Athens. The scope of visits was the Energy Inspection of Buildings in order to focus in main issues that occurs high energy consumption during a typical school year and also to propose technical measures to upgrade the energy efficient of buildings. Along technical visits Engineers recording also the notes and proposals from pupils and Teachers in special meeting that was called “Energy Tour With Pupils”.

The Energy inspection including not only site inspection of building quality and conditions, but also data collection and evaluation from energy consumption (electricity, gas, oil). Based on these for each school a variety of measures proposed with main goal:

- Improving thermal comfort in Educational - School Buildings.
- Reduce of energy consumption, CO2 emissions and operation cost.
- Reduce the wasting of energy that occurred from not proper technical installations.
- Upgrade the operation of heating system.
- Familiarize students with energy-saving practices.

The main methodology that it is applied in this project describe in following paragraphs.

Based on technical visits in schools and meetings with Technical Department of Municipal of Athens, the Engineers Team proceed in:

- Collection of any available data for each building school. The available data were clarified in three main categories
 - A – Existing drawings from building license (architectural, EM, etc)
 - B – Performance on heating system based on yearly check that performed from Technical Department
 - C- Energy Consumption data from bills (electricity, gas, oil)
- Creation Drawings for heating system as an output of technical visit and energy inspection.
- Internal meetings of engineers team in order to summarize the findings of Energy Inspection and make the proposals of small intervention for changing the operation habits and in some cases reduce energy consumptions.
- **Data Base design for buildings.** All the above mention data, notes and proposal stored in a common data base that can be used as a tools for making decision and organize next step in order to achieve the goal of the project. This data base, that present in following paragraphs and is submitted in electronic form, could be used as a general tools not only for the schools that participate in the project but for all the schools of Municipal of Athens.


The schools that participate in the project presented in following table.

Project: Building checks with Pupils

LIST OF SCHOOLS				
ID	NUMBER	TYPE	Address	CODE (ID_NUMBER OF SCHOOL_TYPE OF SCHOOL_ADDRESS)
1	2	Experimental Gymnasium	Filimonos & Tsoxa St, 11521, Athens	01_2_EXPERIMENTAL_GYMNASIUM_FILIMONOS & TSOXA
2	152	Primary School	Miliaraki & Kourtidou St, 11145, Athens	02_152_PRIMARY_SCHOOL_MILIARAKI 59 & KOURTIDOU
3	1	Experimental Gymnasium	114, Adrianou St, 10557, Athens	03_1_EXPERIMENTAL_GYMNASIUM_ANDRIANOU 114
4	21	Primary School	43, Kyprou St, 11253, Athens	04_21_PRIMARY_SCHOOL_KYPROU 43
5	39	Primary School	Axarnwn & Tsounta St, 11143, Athens	05_39_EXPERIMENTAL_SCHOOL_AXARNWN & TSOUNTA
6	43	Gymnasium and Lyceum	2, Asprogeraka St, 11744, Athens	06_43_GYMNASIUM_LYCEUM_ASPROGERAKA 2
7	40	Primary School	Momferatou & Falireos St, 11475, Athens	07_40_PRIMARY_SCHOOL_MOMFERATOY & FALHREOS & RAGAVI
8	22	Primary School	50, Leukosias St, 11253, Athens	08_22_PRIMARY_SCHOOL_LEUKOSIAS 50
9	14	Lyceum	Sikelias & Aglayroy St, 11741, Athens	09_14_LYCEUM_SIKELIAS & AGLAYROY
10	93	Primary School	9, Pytheoy St, 11743, Athens	10_2_PRIMARY_SCHOOL_PYTHEOY 9

GENERAL INFORMATION

School Name	2 Experimental Gymnasium	
School Type	Experimental Gymnasium	
Andrees	Filimonos & Tsoxa St, 11521, Athens	
Director	Makridis Panagiotis/Vicky Gitzia	
Tel	21 0646 5673	
website	http://2gym-peir-athin.att.sch.gr/	
email	mail@2gym-peir-athin.att.sch.gr	
Pupils/ Students	486	
Teachers	48	
Total Users	534	



BUILDING DATA



YEAR OF CONTRUCNTION	1980	LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.	NA	-1 FLOOR	150	
BUILDING PARTS	3	0 FLOOR	1450	
BUILDING FLOORS	3	1th FLOOR	1240	
TOTAL S.M.	4650	2th FLOOR	1240	
m²/ STUDEN	9.57	3th FLOOR	570	
m²/ USER	8.71	4th FLOOR	0	
		SUM	4650	18

BUILDING CONSTRUCTION QUALITY

DESCRIPTION	
FOOTINGS	Uninsullated Concrete
WALLS	Single Brick
BEAMS	Uninsulated Concrete
ROOF	Waterproof Insulation - Bad Quality
WINDOWS	Single Glass with Alluminium frame
DOORS	Iron made doors, with 10% of single glass
SHADING	internal shading - curtains
Notes	


ENERGY CONSUMPTION DATA - SPECIFIC VALUES

CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	64837	NA	NA	NA	64837	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	39800	40440	NA	40120	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	13.94	kWh(th)/y.s.m	121.418	kWh(th)/y.user	12708.052	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	8.63	kWh(el)/y.s.m	75.131	kWh(el)/y.user	39678.68	kg CO2/Year
				TOTAL	52386.732	kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



PUMPS				
No	TYPE	POWER [kW]	FLOW [m ³ /h]	HEAD [m]
P1	WILO TOP S 50/4	0.355	11	4
P2	WILO TOP S 30/7	0.195	5	4
P3	WILO TOP S 50/4	0.355	11	4
P4				

HEATING EQUIPMENT			
No	TYPE	MODEL	HEATING POWER [kW]
1	BOILER	THERMOSTAHL	523
2	GAS BURNER	RIELLO RS-50	115-600

FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	523 kW	THERMOSTAHL
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	115-600 kW	RIELLO RS-50
BURNER 2	kW	
BURNER 3	kW	

TOTAL 523 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m ³ /h]	EL.DATA [kW]
PUMP 1	WILLO TOP S - 50/4	4	11	0.33
PUMP 2	WILLO TOP S - 30/7	4	5	0.195
PUMP 3	WILLO TOP S - 50/4	4	11	0.33
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0.855 kW(el)

MEASUREMENTS (AVARAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	202.6	°C	0	°C		°C
CARBON MONOXIDE	26	ppm	0	ppm		ppm
OXIDE OF NITROGEN	67	ppm	0	ppm		ppm
OXIGEN	5.2	%	0	%		%
CARBON DIOXIDE	8.9	%	0	%		%
GAS PRESSURE	32.2	mbar	0	mbar		mbar
OPARATION GAS PRES	21.3	mbar	0	mbar		mbar
WATER TEMP.	67	°C	0	°C		°C

CALCULATIONS

EFFICIENT	91.9	%	0	%		%
GAS LOSSES	8.1	%	0	%		%
GAS SUPPLY	47.1	m ³ /h	0	m ³ /h		m ³ /h
HEATING CAPACITY / S.M.	112.47	WATTS/s.m				

COOLING SYSTEM		
ROOM	TYPE	
OFFICES	SPLIT UNIT	
CLASS	NA	
GYM	NA	
BOOKSTORE	SPLIT UNIT	
MULTIPURPOSE HALL	SPLIT UNIT	
FRESH AIR SYSTEM - VENTILATORS		
ROOM	TYPE	
OFFICES	FRESH AIR FROM WINDOWS	FLUSH MOUNT SEILING FANS
CLASS	FRESH AIR FROM WINDOWS	
GYM	FRESH AIR FROM WINDOWS	
BOOKSTORE	FRESH AIR FROM WINDOWS	FLUSH MOUNT SEILING FANS
MULTIUSE ROOM	FRESH AIR FROM WINDOWS	FLUSH MOUNT SEILING FANS
LIGHTING		
ROOM	TYPE	
OFFICES	TYPICAL FLUORESCENT LIGHTING	
CLASS	TYPICAL FLUORESCENT LIGHTING	
GYM	TYPICAL FLUORESCENT LIGHTING	
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING	
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING	

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated. The external part, has typical armaflex insulation 13mm, without UV protection. This part are damaged and need to be repair.

2 - PUMPS

Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive.

3 - CHIMNEY

Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 12.00 pm. The is no thermostat in any typical room of school.


5- CLASS OPERATION CONDITIONS

The main air temperature in class was measured from 18-20 °C during winter. Good thermal confort contitions

PROPOSALS FOR UPGRATE

- 1) New insulated chimney according to national standards should be installed
- 2) Maintenance and repair of waterproof roofing system (water insulation)
- 3) Thermal Insulation of pipes and fittings inside the mechanical room
- 4) Thermal Insulation with UV protection of external pipe network
- 5) New switch board with timer for heating system should be installed for more efficient operation



GENERAL INFORMATION		
School Name	152 Primary School	
School Type	Primary School	
Andrees	Miliaraki & Kourtidou St, 11145, Athens	
Director	Besios Antonios	
Tel	2108314280	
website	https://blogs.sch.gr/152dimat/	
email	mail@152dim-athin.att.sch.gr	
Pupils/ Students	200	
Teachers	19	
Total Users	219	



BUILDING DATA					
YEAR OF CONTRUCNTION	1980		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.			-1 FLOOR	-	
BUILDING PARTS	3		0 FLOOR	909.64	
BUILDING FLOORS	3		1th FLOOR	924.91	
TOTAL S.M.	2483.01		2th FLOOR	648.46	
m²/ STUDEN	12.42		3th FLOOR	-	
m²/ USER	11.34		4th FLOOR	-	
			SUM	2483.01	9.00


BUILDING CONSTRUCTION QUALITY	
DESCRIPTION	
FOOTINGS	Uninsulated Concrete
WALLS	Single Brick
BEAMS	Uninsulated Concrete
ROOF	Waterproof Insulation - Good quallity
WINDOWS	Single Glass with Alluminium frame
DOORS	Iron made doors, with 10% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	73694	NA	NA	NA	73694	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	29.68	kWh(th)/y.s.m	336.502	kWh(th)/y.user	14444	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	#ΣΥΝΔΕΣΗ!	kWh(el)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(el)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
			TOTAL		#ΣΥΝΔΕΣΗ!	kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	140 kW	SIME
BOILER 2	185 kW	SIME
BOILER 3	kW	
BURNER 1	65-189 kW	RIELO BS3
BURNER 2	110-249 kW	RIELLO BS4D
BURNER 3	kW	

TOTAL 325 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1	WILLO TOP S - 40/7	5.2	10	0.39
PUMP 2	WILLO TOP S - 40/7	5.2	10	0.39
PUMP 3				
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0.78 kW(el)

MEASUREMENTS (AVARAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1	HEATING SYSTEM 2	HEATING SYSTEM 3
EXHAUST GAS TEMP.	170 °C	198 °C	°C
CARBON MONOXIDE	0 ppm	0 ppm	ppm
OXIDE OF NITROGEN	20 ppm	21 ppm	ppm
OXIGEN	5.4 %	5.1 %	%
CARBON DIOXIDE	8.7 %	8.8 %	%
GAS PRESSURE	28.5 mbar	28.5 mbar	mbar
OPARATION GAS PRES	22.3 mbar	23.1 mbar	mbar
WATER TEMP.	57 °C	65 °C	°C

CALCULATIONS

EFFICIENT	92.4 %	91.1 %	%
GAS LOSSES	7.6 %	8.9 %	%
GAS SUPPLY	13 m³/h	17.8 m³/h	m³/h

HEATING CAPACITY / S.M.	130.89	WATTS/s.m
-------------------------	--------	-----------

COOLING SYSTEM	
ROOM	TYPE
OFFICES	SPLIT UNIT
CLASS	NA
GYM	NA
BOOKSTORE	SPLIT UNIT
MULTIPURPOSE HALL	SPLIT UNIT
FRESH AIR SYSTEM - VENTILATORS	
ROOM	TYPE
OFFICES	FRESH AIR FROM WINDOWS
CLASS	FRESH AIR FROM WINDOWS
GYM	FRESH AIR FROM WINDOWS
BOOKSTORE	FRESH AIR FROM WINDOWS
MULTIUSE ROOM	FRESH AIR FROM WINDOWS
LIGHTING	
ROOM	TYPE
OFFICES	TYPICAL FLUORESCENT LIGHTING
CLASS	TYPICAL FLUORESCENT LIGHTING
GYM	TYPICAL FLUORESCENT LIGHTING
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated. In some cases the radiators are connected vise versa.

2 - PUMPS

Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive.

3 - CHIMNEY

Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 12.00 pm. The is no thermostat in any typical room of school.

5- CLASS OPERATION CONDITIONS

The main air temperature in class was measured from 18-20 °C during winter. Good thermal confort contitions

PROPOSALS FOR UPGRATE

- 1) Thermal Insulation of pipes and fittings inside the mechanical room
- 2) New switch board with timer for heating system should be installed for more efficient operation
- 3) Installation of temperature control unit for heating system based on external conditions in order to avoid overheating of building during hot winder day
- 4) Installation of Air Condition Unit, new led lightings and curtains to stairs in main entrance of school
- 5) Installation of Air Condition Unit and external shading system in classroom for children with special education needs
- 6) Installation data logger for monitoring energy use for heating and electricity



GENERAL INFORMATION		
School Name	1 Experimental Gymnasium	
School Type	Experimental Gymnasium	
Andrees	114, Adrianou St, 10557, Athens	
Director	Kontogiannis Kostis	
Tel	2108314280	
website	http://www.1gympeirath.gr/sxoleio/	
email	1gympeir@sch.gr	
Pupils/ Students	243	
Teachers	26	
Total Users	269	



BUILDING DATA					
YEAR OF CONTRUCNTION	1936		LEVEL	AREA (m ²)	CLASS ROOM
RENOVATION YEAR.	2005		-1 FLOOR	480.72	
BUILDING PARTS	3		0 FLOOR	480.72	
BUILDING FLOORS	3		1th FLOOR	480.72	
TOTAL S.M.	1442.16		2th FLOOR	-	
m ² / STUDEN	5.93		3th FLOOR	-	
m ² / USER	5.36		4th FLOOR	-	
			SUM	1442.16	0.00


BUILDING CONSTRUCTION QUALITY	
DESCRIPTION	
FOOTINGS	Uninsulated Concrete
WALLS	Stone
BEAMS	
ROOF	Roof with tile
WINDOWS	Single Glass Wooden Frame
DOORS	Iron made doors, with 20% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	16354	NA	NA	NA	16354	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	22346	19406	NA	20876	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	11.34	kWh(th)/y.s.m	60.796	kWh(th)/y.user	3205	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	14.48	kWh(el)/y.s.m	77.606	kWh(el)/y.user	20646	kg CO2/Year
				TOTAL	23852	kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



PUMPS				
No	TYPE	POWER [kW]	FLOW [m³/h]	HEAD [m]
P1	WILO TOP S 30/7	0.195	5	4
P2	WILO TOP S 30/7	0.195	5	4
P3				
P4				
HEATING EQUIPMENT				
No	TYPE	MODEL	HEATING POWER [kW]	
1	BOILER	BENTOIL	150	
2	GAS BURNER	RIELLO BS 3	65-189	

FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	150 kW	BENTOIL
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	65-189 kW	RIELLO BS 3
BURNER 2	kW	
BURNER 3	kW	

TOTAL 150 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1				
PUMP 2				
PUMP 3				
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	239.7	°C		°C		°C
CARBON MONOXIDE	35	ppm		ppm		ppm
OXIDE OF NITROGEN	37	ppm		ppm		ppm
OXIGEN	4.4	%		%		%
CARBON DIOXIDE	9.3	%		%		%
GAS PRESSURE	26.3	mbar		mbar		mbar
OPARATION GAS PRES	18.5	mbar		mbar		mbar
WATER TEMP.	67	°C		°C		°C

CALCULATIONS

EFFICIENT	90.9	%		%		%
GAS LOSSES	9.1	%		%		%
GAS SUPPLY	13	m³/h		m³/h		m³/h
HEATING CAPACITY / S.M.	104.01	WATTS/s.m				

COOLING SYSTEM	
ROOM	TYPE
OFFICES	SPLIT UNIT
CLASS	NA
GYM	NA
BOOKSTORE	NA
MULTIPURPOSE HALL	NA
FRESH AIR SYSTEM - VENTILATORS	
ROOM	TYPE
OFFICES	FRESH AIR FROM WINDOWS
CLASS	FRESH AIR FROM WINDOWS
GYM	NA
BOOKSTORE	MECHANICAL VENDILATION
MULTIUSE ROOM	MECHANICAL VENDILATION
LIGHTING	
ROOM	TYPE
OFFICES	TYPICAL FLUORESCENT LIGHTING
CLASS	TYPICAL FLUORESCENT LIGHTING
GYM	TYPICAL FLUORESCENT LIGHTING
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING

DESCRIPTION OF EQUIPMENT AND OPERATION
HEATING SYSTEM DESCRIPTION 1 - HEATING PIPE Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated.
2 - PUMPS Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive.
3 - CHIMNEY Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.
4 - BOILER - BURNER Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 11.00 pm. There is no thermostat in any typical room of school.
5- CLASS OPERATION CONDITIONS The main air temperature in class was measured from 19-22 °C during winter. Good thermal comfort conditions. Low air quality conditions because the classrooms are too small without fresh air system
PROPOSALS FOR UPGRADE 1) Maintenance and regulation of heating system in order to reduce high exhaust gas temperature 2) Thermal Insulation of pipes and fittings inside the mechanical room 3) Installation of air quality data logger to monitor air quality problems 4) Installation of presence detectors in order to control lighting system and Air Conditions in teachers room



GENERAL INFORMATION		
School Name	21 Primary School	
School Type	Primary School	
Andrees	43, Kyprou St, 11253, Athens	
Director	Foutsitzi Chrisoula	
Tel	2108652643	
website	https://blogs.sch.gr/21dimath/	
email	mail@21dim-athin.att.sch.gr	
Pupils/ Students	180	
Teachers	18	
Total Users	198	



BUILDING DATA					
YEAR OF CONTRUCNTION	1899 / 2006		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.	1967		-1 FLOOR	260	
BUILDING PARTS	2		0 FLOOR	540	
BUILDING FLOORS	3		1th FLOOR	540	
TOTAL S.M.	1690		2th FLOOR	350	
m²/ STUDEN	9.39		3th FLOOR	-	
m²/ USER	8.54		4th FLOOR	-	
			SUM	1690	0.00


BUILDING CONSTRUCTION QUALITY	
DESCRIPTION	
FOOTINGS	Uninsulated Concrete
WALLS	Stone
BEAMS	
ROOF	Roof with tile
WINDOWS	Single Glass Wooden Frame
DOORS	Iron made doors, with 20% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	26869	NA	NA	NA	26869	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	15.90	kWh(th)/y.s.m	135.702	kWh(th)/y.user	5266	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	#ΣΥΝΔΕΣΗ!	kWh(el)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(el)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
			TOTAL	#ΣΥΝΔΕΣΗ!		kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	0 kW	0
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	0 kW	0
BURNER 2	kW	
BURNER 3	kW	

TOTAL 0 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1				
PUMP 2				
PUMP 3				
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)


	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	0	°C		°C		°C
CARBON MONOXIDE	0	ppm		ppm		ppm
OXIDE OF NITROGEN	0	ppm		ppm		ppm
OXYGEN	0	%		%		%
CARBON DIOXIDE	0	%		%		%
GAS PRESSURE	0	mbar		mbar		mbar
OPARATION GAS PRES	0	mbar		mbar		mbar
WATER TEMP.	0	°C		°C		°C

CALCULATIONS

EFFICIENT	0	%		%		%
GAS LOSSES	0	%		%		%
GAS SUPPLY	0	m³/h		m³/h		m³/h
HEATING CAPACITY / S.M.	0.00	WATTS/s.m				

COOLING SYSTEM	
ROOM	TYPE
OFFICES	SPLIT UNIT
CLASS	NA
GYM	NA
BOOKSTORE	SPLIT UNIT
MULTIPURPOSE HALL	SPLIT UNIT
FRESH AIR SYSTEM - VENTILATORS	
ROOM	TYPE
OFFICES	FRESH AIR FROM WINDOWS
CLASS	FRESH AIR FROM WINDOWS
GYM	FRESH AIR FROM WINDOWS
BOOKSTORE	FRESH AIR FROM WINDOWS
MULTIUSE ROOM	FRESH AIR FROM WINDOWS
LIGHTING	
ROOM	TYPE
OFFICES	TYPICAL FLUORESCENT LIGHTING
CLASS	TYPICAL FLUORESCENT LIGHTING
GYM	TYPICAL FLUORESCENT LIGHTING
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING



PROPOSALS FOR UPGRADE


GENERAL INFORMATION		
School Name	39 Primary School	
School Type	Primary School	
Andrees	Axarnwn & Tsounta St, 11143, Athens	
Director	Aloukos Giorgos	
Tel	2108652643	
website	http://39dim-athin.att.sch.gr/	
email	mail@39dim-athin.att.sch.gr	
Pupils/ Students	226	
Teachers	33	
Total Users	259	

BUILDING DATA					
YEAR OF CONTRUCNTION	1979	LEVEL	AREA (m²)	CLASS ROOM	
RENOVATION YEAR.	0	-1 FLOOR	0		
BUILDING PARTS	3	0 FLOOR	904.07		
BUILDING FLOORS	3	1th FLOOR	597.68		
TOTAL S.M.	2099.43	2th FLOOR	597.68		
m²/ STUDEN	9.29	3th FLOOR	0		
m²/ USER	8.11	4th FLOOR	2099.43		
		SUM	4198.86	0.00	

BUILDING CONSTRUCTION QUALITY	
	DESCRIPTION
FOOTINGS	Uninsulated Concrete
WALLS	Uninsulated Concrete
BEAMS	Uninsulated Concrete
ROOF	Waterproof Insulation - Good quality
WINDOWS	Single Glass with Alluminium frame
DOORS	Iron made doors, with 10% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	30952	36486	NA	33719	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	#ΣΥΝΔΕΣΗ!	kWh(th)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(th)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	8.03	kWh(el)/y.s.m	130.189	kWh(el)/y.user	33348	kg CO2/Year
				TOTAL	#ΣΥΝΔΕΣΗ!	kg CO2/Year



HEATING SYSTEM DESCRIPTION**DRAFT HEATING SYSTEM DRAWING**NOTESNOT AVAILABLE DATA FROM TECHNICAL VISIT

PUMPS				
No	TYPE	POWER [kW]	FLOW [m³/h]	HEAD [m]
P1				
P2				
P3				
P4				
HEATING EQUIPMENT				
No	TYPE	MODEL	HEATING POWER [kW]	
1	BOILER	PYRKAL	255	
2	GAS BURNER	RIELLO RS 5D	160-206/ 34	

FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	255.85 kW	PYRKAL
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	160-208 / 345 kW	RIELLO RS 5D
BURNER 2	kW	
BURNER 3	kW	

TOTAL 255.85 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1				
PUMP 2				
PUMP 3				
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	228.5	°C		°C		°C
CARBON MONOXIDE	14	ppm		ppm		ppm
OXIDE OF NITROGEN	91	ppm		ppm		ppm
OXIGEN	4.5	%		%		%
CARBON DIOXIDE	9.3	%		%		%
GAS PRESSURE	32.5	mbar		mbar		mbar
OPARATION GAS PRES	23	mbar		mbar		mbar
WATER TEMP.	70	°C		°C		°C

CALCULATIONS

EFFICIENT	90.4	%		%		%
GAS LOSSES	9.6	%		%		%
GAS SUPPLY	21	m³/h		m³/h		m³/h
HEATING CAPACITY / S.M.	60.93	WATTS/s.m				

COOLING SYSTEM		
ROOM	TYPE	
OFFICES	SPLIT UNIT	
CLASS	NA	
GYM	NA	
BOOKSTORE	SPLIT UNIT	
MULTIPURPOSE HALL	SPLIT UNIT	
FRESH AIR SYSTEM - VENTILATORS		
ROOM	TYPE	
OFFICES	MECHANICAL VENTILATION	FLUSH MOUNT SEILING FANS
CLASS	MECHANICAL VENTILATION	FLUSH MOUNT SEILING FANS
GYM	MECHANICAL VENTILATION	
BOOKSTORE	MECHANICAL VENTILATION	
MULTIUSE ROOM	MECHANICAL VENTILATION	
LIGHITING		
ROOM	TYPE	
OFFICES	TYPICAL FLUORESCENT LIGHTING	
CLASS	TYPICAL FLUORESCENT LIGHTING	
GYM	TYPICAL FLUORESCENT LIGHTING	
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING	
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING	

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Heating pipes are made from black iron in several diameters.

2 - PUMPS**3 - CHIMNEY**

Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C.

The control strategy of heating system is: Manual On - Off based on daily schedule.

5- CLASS OPERATION CONDITIONS


The main air temperature in class was measured from 18-20 °C during winter. Good thermal confort contitions

PROPOSALS FOR UPGRATE

- 1) Installation of two way motorized valve in order to separate the heating system of the two building block
- 2) Installation thermostat in one typical classroom for each building block - ON/Of motorized valve and boiler
- 3) Change water taps for demostation
- 4) Installation of new light (Led) and change the switch on in two rows
- 5) Maintenance and regulation of mechanical vantillation system

--



GENERAL INFORMATION		
School Name	43 Gymnasium and Lyceum	
School Type	Lyceum	
Andrees	2, Asprogeraka St, 11744, Athens	
Director	Orfanoudaki Eirini	
Tel	2108652643	
website	http://43gym-athin.att.sch.gr/autosch/joomla1	
email	mail@43lyk-athin.att.sch.gr	
Pupils/ Students	500	
Teachers	0	
Total Users	500	



BUILDING DATA					
YEAR OF CONTRUCNTION	1972		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.	0		-1 FLOOR	779.27	
BUILDING PARTS	6		0 FLOOR	1863.28	
BUILDING FLOORS	3		1th FLOOR	1184.65	
TOTAL S.M.	4547.17		2th FLOOR	719.97	
m²/ STUDEN	9.09		3th FLOOR	0	
m²/ USER	9.09		4th FLOOR	0	
			SUM	4547.17	0.00


BUILDING CONSTRUCTION QUALITY	
DESCRIPTION	
FOOTINGS	Uninsulated Concrete
WALLS	Uninsulated Concrete - Singe brick
BEAMS	
ROOF	Waterproof Insulation - good quallity
WINDOWS	Single Glass aluminium frame
DOORS	Iron made doors, with 30% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	66905.00	82763	NA	NA	66905.00	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	14.71	kWh(th)/y.s.m	133.810	kWh(th)/y.user	13113	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	#ΣΥΝΔΕΣΗ!	kWh(el)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(el)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
			TOTAL		#ΣΥΝΔΕΣΗ!	kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	581 kW	THERMOSTAHL
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	191-814 kW	RIELLO RS 70
BURNER 2	kW	
BURNER 3	kW	

TOTAL 581 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1	WILO S50/140 r	8	15	1550 BUCK UP
PUMP 2	WILO S50/140 r	8	15	1550
PUMP 3	WILO S50/140 r	8	15	1550
PUMP 4	WILO S50/140 r	8	15	1550 BUCK UP
PUMP 5				
PUMP 6				

TOTAL 6200 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	210.3	°C		°C		°C
CARBON MONOXIDE	19	ppm		ppm		ppm
OXIDE OF NITROGEN	69	ppm		ppm		ppm
OXIGEN	7.5	%		%		%
CARBON DIOXIDE	9.3	%		%		%
GAS PRESSURE	64.6	mbar		mbar		mbar
OPARATION GAS PRES	40.1	mbar		mbar		mbar
WATER TEMP.	65	°C		°C		°C

CALCULATIONS

EFFICIENT	92.1	%		%		%
GAS LOSSES	7.9	%		%		%
GAS SUPPLY	0	m³/h		m³/h		m³/h
HEATING CAPACITY / S.M.	127.77	WATTS/s.m				

COOLING SYSTEM	
ROOM	TYPE
OFFICES	SPLIT UNIT
CLASS	NA
GYM	NA
BOOKSTORE	NA
MULTIPURPOSE HALL	NA
FRESH AIR SYSTEM - VENTILATORS	
ROOM	TYPE
OFFICES	FRESH AIR FROM WINDOWS
CLASS	FRESH AIR FROM WINDOWS
GYM	FRESH AIR FROM WINDOWS
BOOKSTORE	FRESH AIR FROM WINDOWS
MULTIUSE ROOM	FRESH AIR FROM WINDOWS
LIGHTING	
ROOM	TYPE
OFFICES	TYPICAL FLUORESCENT LIGHTING
CLASS	TYPICAL FLUORESCENT LIGHTING
GYM	TYPICAL FLUORESCENT LIGHTING
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated. The external part, has typical armaflex insulation 13mm, without UV protection. This part are damaged and need to be repair.

2 - PUMPS

Pumps are constant speed driven and working in paraller without any control (non stop operation). Should be Immediately change with inverter driven pumps based on EUP 2015 directive.

3 - CHIMNEY

Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 14.00 pm. The is no thermostat in any typical room of school.

5- CLASS OPERATION CONDITIONS

Extremly different temperature per class and per floor.

PROPOSALS FOR UPGRATE

- 1) Thermal Insulation of pipes and fittings inside the mechanical room
- 2) Maintenance and regulation of heating system in order to reduce high exhaust gas temperature
- 3) New switch board with timer for heating system should be installed for more efficient operation
- 4) Installation of new pumps and temperature control of their operation
- 5) Installation of flush mounted seiling fans in classroom
- 6) Installation new Air Condition Unit in teachers room - office
- 7) Installation new Air Condition Unit in PC lab
- 8) Check and repair the main electrical installation and switchboards per floor



GENERAL INFORMATION		
School Name	40 Primary School	
School Type	Primary School	
Andrees	Momferatou & Falireos St, 11475, Athens	
Director	Mpoukogianni Marillena	
Tel	2108652643	
website	https://blogs.sch.gr/40dimat/	
email	mail@40dim-athin.att.sch.gr	
Pupils/ Students	220	
Teachers	23	
Total Users	243	



BUILDING DATA					
YEAR OF CONTRUCNTION	1991		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.	0		-1 FLOOR	91.54	
BUILDING PARTS	2		0 FLOOR	681.9	
BUILDING FLOORS	3		1th FLOOR	608.55	
TOTAL S.M.	1823.92		2th FLOOR	393.96	
m²/ STUDEN	8.29		3th FLOOR	47.97	
m²/ USER	7.51		4th FLOOR	-	
			SUM	1823.92	0.00


BUILDING CONSTRUCTION QUALITY	
DESCRIPTION	
FOOTINGS	Uninsulated Concrete
WALLS	Uninsulated Concrete
BEAMS	
ROOF	Waterproof Insulation - mean quality
WINDOWS	New double Glass alluminium frame
DOORS	Iron made doors, with 20% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	17156.00	19306.00	NA	NA	18231	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	10.00	kWh(th)/y.s.m	75.025	kWh(th)/y.user	3573	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	#ΣΥΝΔΕΣΗ!	kWh(el)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(el)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
			TOTAL	#ΣΥΝΔΕΣΗ!		kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



PUMPS				
No	TYPE	POWER [kW]	FLOW [m ³ /h]	HEAD [m]
P1	WILO S 40/7	0.13	5	4
P2	WILO 40/70	0.255	5	4
P3				
P4				
HEATING EQUIPMENT				
No	TYPE	MODEL	HEATING POWER [kW]	
1	BOILER	UNNAME	140	
2	GAS BURNER	RIELLO BS 3	65-189	

FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	140 kW	UNNAME
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	65-189 kW	RIELLO BS 3
BURNER 2	kW	
BURNER 3	kW	

TOTAL 140 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m ³ /h]	EL.DATA [kW]
PUMP 1	WILLO S - 40/7	5.2	10	0.13
PUMP 2	WILLO - 40/7	5.2	10	0.226
PUMP 3				
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0.356 kW(el)

MEASUREMENTS (AVARAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	175	°C		°C		°C
CARBON MONOXIDE	3	ppm		ppm		ppm
OXIDE OF NITROGEN	37	ppm		ppm		ppm
OXIGEN	5.3	%		%		%
CARBON DIOXIDE	8.8	%		%		%
GAS PRESSURE	29.4	mbar		mbar		mbar
OPARATION GAS PRES	22.2	mbar		mbar		mbar
WATER TEMP.	70	°C		°C		°C

CALCULATIONS

EFFICIENT	93.1	%		%		%
GAS LOSSES	6.9	%		%		%
GAS SUPPLY	12	m ³ /h		m ³ /h		m ³ /h
HEATING CAPACITY / S.M.	76.76	WATTS/s.m				

COOLING SYSTEM		
ROOM	PART1	
OFFICES	SPLIT UNIT	
CLASS	NA	
GYM	NA	
BOOKSTORE	SPLIT UNIT	
MULTIPURPOSE HALL	SPLIT UNIT	
FRESH AIR SYSTEM - VENTILATORS		
ROOM	TYPE	
OFFICES	MECHANICAL VENTILLATION	FLUSH MOUNTED SEILING FANS
CLASS	MECHANICAL VENTILLATION	FLUSH MOUNTED SEILING FANS
GYM	MECHANICAL VENTILLATION	FLUSH MOUNTED SEILING FANS
BOOKSTORE	MECHANICAL VENTILLATION	FLUSH MOUNTED SEILING FANS
MULTIUSE ROOM	MECHANICAL VENTILLATION	FLUSH MOUNTED SEILING FANS
LIGHITING		
ROOM	TYPE	
OFFICES	TYPICAL FLUORESCENT LIGHTING	
CLASS	TYPICAL FLUORESCENT LIGHTING	
GYM	TYPICAL FLUORESCENT LIGHTING	
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING	
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING	

DESCRIPTION OF EQUIPMENT AND OPERATION**HEATING SYSTEM DESCRIPTION****1 - HEATING PIPE**

Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated. The external part, has typical armaflex insulation 13mm, with UV protection.

2 - PUMPS

Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive.

3 - CHIMNEY

Chimney of boiler is based on national regulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 12.00 pm. There is no thermostat in any typical room of school.


5- CLASS OPERATION CONDITIONS

The main air temperature in class was measured from 18-20 °C during winter. Good thermal comfort conditions. In each room mechanical ventilation had been installed and occurs high noise during operation. regulation needed.

PROPOSALS FOR UPGRADE

- 1) Maintenance and repair of waterproof roofing system (water insulation)
- 2) Installation of temperature control unit for heating system based on external conditions in order to avoid overheating of building during hot winter day
- 3) Maintenance and regulation of mechanical ventilation per classroom
- 4) Installation data logger for monitoring energy use for heating and electricity



GENERAL INFORMATION		
School Name	22 Primary School	
School Type	Primary School	
Andrees	50, Leukosias St, 11253, Athens	
Director	Maganaris Nikolaos	
Tel	2108652643	
website	http://22dim-athin.att.sch.gr/index.php	
email	mail@22dim-athin.att.sch.gr	
Pupils/ Students	150	
Teachers	22	
Total Users	172	



BUILDING DATA					
YEAR OF CONTRUCNTION	1900 / 2011		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.	0		-1 FLOOR	36.6	
BUILDING PARTS	3		0 FLOOR	408.89	
BUILDING FLOORS	3		1th FLOOR	473.81	
TOTAL S.M.	1290.03		2th FLOOR	335.17	
m²/ STUDEN	8.60		3th FLOOR	35.56	
m²/ USER	7.50		4th FLOOR	-	
			SUM	1290.03	0.00


BUILDING CONSTRUCTION QUALITY		
	DESCRIPTION OLD BUILDING	DESCRIPTION NEW BUILDING
FOOTINGS		Concrete
WALLS	Stone	Concrete
BEAMS		
ROOF	Roof with tile	Waterproof Insulation - good quallity
WINDOWS	Double glass - aluminum frame	New double Glass aluminium frame
DOORS	Iron made doors, with 20% of single glass	Iron made doors, with 20% of single glass
SHADING	internal shading - curtains	internal shading - curtains
Notes		

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	19989.00	17468	NA	NA	19989	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	15.49	kWh(th)/y.s.m	116.215	kWh(th)/y.user	3918	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	#ΣΥΝΔΕΣΗ!	kWh(el)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(el)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
				TOTAL	#ΣΥΝΔΕΣΗ!	kg CO2/Year



HEATING SYSTEM DESCRIPTION

DRAFT HEATING SYSTEM DRAWING



FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	104 kW	FINOTHERM
BOILER 2	68.6 kW	BLUCALOR
BOILER 3	kW	
BURNER 1	65-189 kW	RIELLO BS 3
BURNER 2	49.8-120 kW	LAMBORGHINI
BURNER 3	kW	

TOTAL 172.6 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1	WILO 30/80 R			0.205
PUMP 2	WILO STAR RS 25/4	2	1.5	0.048
PUMP 3	WILO MAXO 30/05-7	4	6	0.12
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0.373 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	189.9	°C	NA	°C		°C
CARBON MONOXIDE	39	ppm	NA	ppm		ppm
OXIDE OF NITROGEN	21	ppm	NA	ppm		ppm
OXIGEN	6	%	NA	%		%
CARBON DIOXIDE	8.5	%	NA	%		%
GAS PRESSURE	27.4	mbar	NA	mbar		mbar
OPARATION GAS PRES	19.6	mbar	NA	mbar		mbar
WATER TEMP.	70	°C	NA	°C		°C

CALCULATIONS

EFFICIENT	92.2	%	NA	%		%
GAS LOSSES	7.8	%	NA	%		%
GAS SUPPLY	8	m3/h	NA	m3/h		m3/h
HEATING CAPACITY / S.M.	133.80	WATTS/s.m				

COOLING SYSTEM		
ROOM	PART 1 (OLD)	PART 2 (NEW)
OFFICES	SPLIT UNIT	VRV
CLASS	NA	VRV
GYM	NA	VRV
BOOKSTORE	SPLIT UNIT	VRV
MULTIPURPOSE HALL	SPLIT UNIT	VRV
FRESH AIR SYSTEM - VENTILATORS		
ROOM	TYPE	
OFFICES	FRESH AIR FROM WINDOWS	FLUSH MOUNTED SEILING FANS
CLASS	FRESH AIR FROM WINDOWS	FLUSH MOUNTED SEILING FANS
GYM	FRESH AIR FROM WINDOWS	FLUSH MOUNTED SEILING FANS
BOOKSTORE	FRESH AIR FROM WINDOWS	FLUSH MOUNTED SEILING FANS
MULTIUSE ROOM	FRESH AIR FROM WINDOWS	FLUSH MOUNTED SEILING FANS
LIGHTING		
ROOM	TYPE	
OFFICES	TYPICAL FLUORESCENT LIGHTING	
CLASS	TYPICAL FLUORESCENT LIGHTING	
GYM	TYPICAL FLUORESCENT LIGHTING	
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING	
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING	

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Old building: Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated. New building: Heating pipes are made from copper and is well insulated

2 - PUMPS

Old Building: Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive. New Building: Pumps are inverter driven pumps and control from thermostat and timer.

3 - CHIMNEY

Old Building: Chimney of boiler is uninsulated and does not cover the national regulations for construction material and external insulation. New Building: Chimney cover the national regulations.

4 - BOILER - BURNER

Old Building: Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. New building the boiler it is not operate. Heating of building covered from VRV

The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 12.00 pm.

5- CLASS OPERATION CONDITIONS

The main air temperature in class was measured from 18-20 °C during winter. Good thermal comfort conditions

PROPOSALS FOR UPGRADE

New Building

- 1) Maintenance and repair heating system
- 2) Maintenance of VRV for cooling and heating. Clean the air filters to upgrade air quality.

Old Building

- 1) New switch board with timer for heating system should be installed for more efficient operation
- 2) Installation of temperature control unit for heating system based on external conditions in order to avoid overheating of building during hot winter day



GENERAL INFORMATION		
School Name	14 Lyceum	
School Type	Primary School	
Andrees	Sikelias & Aglayroy St, 11741, Athens	
Director	Mavrogiannakis Leonidas	
Tel	2108652643	
website	http://14lyk-athin.att.sch.gr/wp3/	
email	mail@14lyk-athin.att.sch.gr	
Pupils/ Students	196	
Teachers	21	
Total Users	42	




BUILDING DATA					
YEAR OF CONTRUCNTION	1982/ 2000		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.			-1 FLOOR	285.86	
BUILDING PARTS	3		0 FLOOR	1053.9	
BUILDING FLOORS	3		1th FLOOR	965.87	
TOTAL S.M.	3314.48		2th FLOOR	965.87	
m²/ STUDEN	16.91		3th FLOOR	42.98	
m²/ USER	78.92		4th FLOOR	0	
			SUM	3314.48	9.00

BUILDING CONSTRUCTION QUALITY		
	DESCRIPTION OLD BUILDING	DESCRIPTION OLD BUILDING
FOOTINGS	Uninsulated Concrete	na data
WALLS	Uninsulated Concrete	Insulated Concrete
BEAMS	Uninsulated Concrete	Insulated Concrete
ROOF	Waterproof Insulation - Good quality	Waterproof Insulation - Good quality
WINDOWS	Single Glass with Aluminium frame	Double Glass with Aluminium frame
DOORS	Iron made doors, with 10% of single glass	Iron made doors, with 30% of single glass
SHADING	internal shading - curtains	internal shading - curtains
Notes		

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	32400	36418.00	NA	NA	34409	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	17395	41218.5	NA	29306.75	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	10.38	kWh(th)/y.s.m	819.262	kWh(th)/y.user	6744	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	8.84	kWh(el)/y.s.m	697.780	kWh(el)/y.user	28984.37575	kg CO2/Year
				TOTAL	35728.53975	kg CO2/Year



HEATING SYSTEM DESCRIPTION**DRAFT HEATING SYSTEM DRAWING**

FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	209 kW	NIKOLSON
BOILER 2	150 kW	THERMOSTAHL
BOILER 3	kW	
BURNER 1	24-140 kW	RIELLO BS 40
BURNER 2	65-189 kW	RIELLO BS 3
BURNER 3	kW	

TOTAL 359 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1	WILLO			0.17
PUMP 2	WILLO STAR RS 30/6	4	2	0.093
PUMP 3	WILLO TOP S 40/4	4	5	0.195
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0.458 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1	HEATING SYSTEM 2	HEATING SYSTEM 3
EXHAUST GAS TEMP.	219.9 °C	219.9 °C	°C
CARBON MONOXIDE	33 ppm	3.3 ppm	ppm
OXIDE OF NITROGEN	38 ppm	38 ppm	ppm
OXIGEN	4.2 %	4.8 %	%
CARBON DIOXIDE	9.1 %	9.1 %	%
GAS PRESSURE	28.7 mbar	23.7 mbar	mbar
OPARATION GAS PRES	19.9 mbar	19.5 mbar	mbar
WATER TEMP.	67 °C	66 °C	°C

CALCULATIONS

EFFICIENT	91.5 %	91.5 %	%
GAS LOSSES	8.5 %	8.5 %	%
GAS SUPPLY	19.2 m³/h	13 m³/h	m³/h
HEATING CAPACITY / S.M.	108.31	WATTS/s.m	

COOLING SYSTEM	
ROOM	TYPE
OFFICES	SPLIT UNIT
CLASS	NA
GYM	NA
BOOKSTORE	SPLIT UNIT
MULTIPURPOSE HALL	SPLIT UNIT
FRESH AIR SYSTEM - VENTILATORS	
ROOM	TYPE
OFFICES	FRESH AIR FROM WINDOWS
CLASS	FRESH AIR FROM WINDOWS
GYM	FRESH AIR FROM WINDOWS
BOOKSTORE	FRESH AIR FROM WINDOWS
MULTIUSE ROOM	FRESH AIR FROM WINDOWS
LIGHTING	
ROOM	TYPE
OFFICES	TYPICAL FLUORESCENT LIGHTING
CLASS	TYPICAL FLUORESCENT LIGHTING
GYM	TYPICAL FLUORESCENT LIGHTING
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated.

2 - PUMPS

Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive.

3 - CHIMNEY

Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C.

The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 10.30 pm. There is no thermostat in any typical room of school.


5- CLASS OPERATION CONDITIONS

The main air temperature in class was measured from 13-16 °C during winter. Very bad thermal comfort conditions due to operation strategy

PROPOSALS FOR UPGRADE

- 1) New switch board with timer for heating system should be installed for more efficient operation
- 2) Installation of temperature control unit for heating system in both buildings, based on external conditions in order to avoid extremely low temperature in some cases.
- 3) Change lighting system in old building



GENERAL INFORMATION		
School Name	93 Primary School	
School Type	Primary School	
Andrees	9, Pytheoy St, 11743, Athens	
Director	Protapappa Stalla	
Tel	2108652643	
website	https://blogs.sch.gr/93dimath/	
email	mail@93dim-athin.att.sch.gr	
Pupils/ Students	374	
Teachers	27	
Total Users	401	




BUILDING DATA					
YEAR OF CONTRUCNTION	1900 / 2011		LEVEL	AREA (m²)	CLASS ROOM
RENOVATION YEAR.	0		-1 FLOOR	330	
BUILDING PARTS	2		0 FLOOR	1030	
BUILDING FLOORS	3		1th FLOOR	1030	
TOTAL S.M.	2760		2th FLOOR	370	
m²/ STUDEN	6.88		3th FLOOR	0	
m²/ USER	6.88		4th FLOOR	-	
			SUM	2760	0.00

BUILDING CONSTRUCTION QUALITY	
DESCRIPTION	
FOOTINGS	Uninsulated Concrete
WALLS	double bricks
BEAMS	Uninsulated Concrete
ROOF	Waterproof Insulation - Very bad quality
WINDOWS	Single Glass with Aluminium frame
DOORS	Iron made doors, with 10% of single glass
SHADING	internal shading - curtains
Notes	

ENERGY CONSUMPTION DATA - SPECIFIC VALUES						
CONSUMPTIONS	2016	2017	2018	2019	AVERAGE	
NATURAL GAS	99051.00	93857	NA	NA	99051	kWh(th)/year
OIL	0	0	0	0	0	lt/year
ELECTRICITY	NA	NA	NA	NA	#ΣΥΝΔΕΣΗ!	kWh(el)/year
SPECIFIC ENERGY	Per Building Area		Per User		CO2 EMISSIONS	
NATURAL GAS	35.89	kWh(th)/y.s.m	247.010	kWh(th)/y.user	19414	kg CO2/Year
OIL	0.00	lt/year.s.m	0.000	lt/y.user		kg CO2/Year
ELECTRICITY	#ΣΥΝΔΕΣΗ!	kWh(el)/y.s.m	#ΣΥΝΔΕΣΗ!	kWh(el)/y.user	#ΣΥΝΔΕΣΗ!	kg CO2/Year
			TOTAL		#ΣΥΝΔΕΣΗ!	kg CO2/Year



HEATING SYSTEM DESCRIPTION**DRAFT HEATING SYSTEM DRAWING**

FUEL TYPE	GASS	PRODUCT DESCRIPTION
BOILER 1	407 kW	THERMOSTAHL
BOILER 2	kW	
BOILER 3	kW	
BURNER 1	105-440 kW	RIELLO RS 38
BURNER 2	kW	
BURNER 3	kW	

TOTAL 407 kW(thl)

CIRCULATORS	TYPE	Head [m]	flow [m³/h]	EL.DATA [kW]
PUMP 1	WILO RS 50			0.09
PUMP 2	WILO TOP S 40/7			0.39
PUMP 3	WILO RS 50			0.09
PUMP 4				
PUMP 5				
PUMP 6				

TOTAL 0.57 kW(el)

MEASUREMENTS (AVERAGE VALUE FROM AVAILABLE DATA)

	HEATING SYSTEM 1		HEATING SYSTEM 2		HEATING SYSTEM 3	
EXHAUST GAS TEMP.	195.7	°C		°C		°C
CARBON MONOXIDE	0	ppm		ppm		ppm
OXIDE OF NITROGEN	59	ppm		ppm		ppm
OXIGEN	5	%		%		%
CARBON DIOXIDE	9	%		%		%
GAS PRESSURE	28.8	mbar		mbar		mbar
OPARATION GAS PRES	20.7	mbar		mbar		mbar
WATER TEMP.	70	°C		°C		°C

CALCULATIONS

EFFICIENT	92.4	%		%		%
GAS LOSSES	7.6	%		%		%
GAS SUPPLY	28	m³/h		m³/h		m³/h
HEATING CAPACITY / S.M.	147.46	WATTS/s.m				

COOLING SYSTEM		
ROOM	TYPE	
OFFICES	SPLIT UNIT	<u>FLUSH MOUNTED</u> SEILING FANS
CLASS	NA	<u>FLUSH MOUNTED</u> SEILING FANS
GYM	NA	
BOOKSTORE	SPLIT UNIT	
MULTIPURPOSE HALL	SPLIT UNIT	
FRESH AIR SYSTEM - VENTILATORS		
ROOM	TYPE	
OFFICES	FRESH AIR FROM WINDOWS	MECHANICAL VENTILATION DOES NOT OPERATE
CLASS	FRESH AIR FROM WINDOWS	MECHANICAL VENTILATION DOES NOT OPERATE
GYM	FRESH AIR FROM WINDOWS	MECHANICAL VENTILATION DOES NOT OPERATE
BOOKSTORE	FRESH AIR FROM WINDOWS	MECHANICAL VENTILATION DOES NOT OPERATE
MULTIUSE ROOM	FRESH AIR FROM WINDOWS	MECHANICAL VENTILATION DOES NOT OPERATE
LIGHTING		
ROOM	TYPE	
OFFICES	TYPICAL FLUORESCENT LIGHTING	
CLASS	TYPICAL FLUORESCENT LIGHTING	
GYM	TYPICAL FLUORESCENT LIGHTING	
BOOKSTORE	TYPICAL FLUORESCENT LIGHTING	
MULTIUSE ROOM	TYPICAL FLUORESCENT LIGHTING	

DESCRIPTION OF EQUIPMENT AND OPERATION

HEATING SYSTEM DESCRIPTION

1 - HEATING PIPE

Heating pipes are made from black iron in several diameters. The internal part of pipe network are uninsulated. In some cases the radiators are connected vice versa.

2 - PUMPS

Pumps are constant speed driven and the operation is controlled by water temperature in supply line of boiler. In case of damage need to be changed from inverter driven pumps based on EUP 2015 directive.

3 - CHIMNEY

Chimney of boiler is uninsulated and does not cover the national regulation for construction material and external insulation.

4 - BOILER - BURNER

Boiler operation temperature is constant all over the heating period. Main Operation temperatures are 65-70 °C. There is an already installed temperature controller but it was never been operate

The control strategy of heating system is: Manual On - Off based on daily schedule. Typical operation hours from 7.30 pm to 11.00 pm.

5- CLASS OPERATION CONDITIONS

Extremely different temperature per class and per floor. Special problem exist in uper floor of building

PROPOSALS FOR UPGRATE

- 1) Maintenance and repair of waterproof roofing system (water insulation)
- 2) Reinstallation of temperature control unit for heating system based on external conditions for better oparation end energy consumption reduce
- 3) Maintenance and regulation of mechanical ventillation per classroom
- 4) Special study for heating network pipe distribution and recalculate radiators heat capacity